



ENVIRONMENTAL HEALTH DIVISION

424 South Castell Avenue
 New Braunfels, TX 78130
 Office - 830-221-4070; Fax – 830-608-2109
 Email: healthdept@nbtexas.org
www.NBTEXAS.org

**Public
 Swimming Pools and
 Spas**

Facility Name:		Date:	
County: COMAL / GUADALUPE		Phone:	
Facility Address:		City/Zip: NEW BRAUNFELS	
Mailing Address:		City/State/Zip:	
Facility Owner:		<input type="checkbox"/> Pre-10/01/99 <input type="checkbox"/> Class A <input type="checkbox"/> Class B <input type="checkbox"/> Class C <input type="checkbox"/> Post-10/01/99 <input type="checkbox"/> Spa <input type="checkbox"/> Wade <input type="checkbox"/> w/PIWF	
Inspection Type: <input type="checkbox"/> Routine <input type="checkbox"/> Complaint <input type="checkbox"/> Re-Inspection <input type="checkbox"/> Pre-Licensing <input type="checkbox"/> Other (specify):			

“X” indicates an alleged deficiency “COS” indicates corrected on site *Items in italics apply to post-10/01/99 pools and spas*

Swimming Pool			
1. Chlorine (1-8 ppm)	Bromine (2.5-12 ppm)	36. Filter on pre-10/01/99 pool or spa functioning.	
2. pH (7.0 - 7.8)		37. Pump vacuum/inlet/outlet gauges & flowmeter.	
3. Cyanuric acid (100 ppm or less)		38. Heater over 200,000 BTU with TDLR certificate.	
4. Deck & sidewall depth markers permanent with 4" numbers.		39. Exposed piping labeled to identify function & flow direction.	
5. Markers at max. & min. depth, breakpoint & 2' depth intervals.		<i>40. Filter on post-10/01/99 pool or spa functioning.</i>	
6. Minimum 2 entry exits.		<i>41. Strainer on pump.</i>	
<i>7. Depth markers no more than 25 feet apart.</i>		Operation, Water Quality & Structural Design	
<i>8. Depth markers – feet and / or inches 4" letters.</i>		42. DPD test kit.	
Wade Pool		43. Automatic chlorinator installed and operational.	
9. Chlorine (1-8 ppm)	Bromine (2.5-12 ppm)	44. No algae.	
10. pH (7.0 – 7.8)		45. Water clear – deepest point of pool / spa clearly visible.	
11. Cyanuric acid (100 ppm or less)		46. Skimmer basket not used to dispense sanitizer.	
12. Deck & sidewall depth markers permanent with 4" numbers.		47. Skimmer cover securely in place.	
<i>13. Depth markers no more than 25 feet apart.</i>		48. Pool / spa bottom and sides light color or white.	
<i>14. Depth markers – feet and / or inches 4" letters.</i>		<i>49. 1 x 1 stripe on leading edge of benches & water lounges.</i>	
<i>15. Wade pool 15 feet from shallow / 35 feet from deepwater areas.</i>		<i>50. 1 x 1 stripe on leading edge of underwater / swimout steps.</i>	
<i>16. Wade pool fenced separately from pool / spa.</i>		Electrical	
<i>17. Wade pool w/ independent circulatory / sanitization system.</i>		51. Lights in pool / spa equipped with GFCI(s).	
Spa		52. Pool / spa yard & bathhouse electrical outlet(s) with GFCI(s).	
18. Chlorine (2-8 ppm)	Bromine (4.5-12 ppm)	53. Pump(s) grounded and bonded.	
19. pH (7.0 – 7.8)		54. Service electrical disconnect w/in sight of pool / spa equipment.	
20. Cyanuric acid (100 ppm or less)		Fill Water/Drinking Water	
21. Temperature 104°F or less / Spa thermometer available to users.		55. Fill water potable supply.	
22. Emergency shutoff in sight & minimum 5 ft. away.		56. Water distribution system protected against backflow.	
23. Maximum user load limit sign provided.		57. Over-the-rim fill spout with secure soft pliable end.	
24. “Do Not Use Spa if Temp. Is Above 104°F” – 1 in. letters.		58. Drinking water available.	
25. “Children Should Not Use Spa w/o Adult Supervision” – 2”.		Specific Safety Features – No Diving Markers & Transition Line	
26. Minimum 2 permanent deck depth markers with 4” numbers.		59. Min. 2-4" “NO DIVING” letters & symbol no more than 25' apart.	
<i>27. 15 min timer-switch minimum 5 feet away from spa.</i>		60. 4" x 4" line on bottom at transition from shallow to deep.	
<i>28. Depth marker feet and / or inches in 4” letters.</i>		Specific Safety Features - Signage	
Suction Outlets (Main Drains)		61. Sign(s) visible to pool / spa user in all areas of pool / spa yard.	
29. Suction outlet cover(s) / grate(s) intact and in place.		62. NO DIVING - 4" letters and symbol.	
30. Single suction outlet-SVRD or AVS installed.		63. WARNING-NO LIFEGUARD ON DUTY - 4" letters.	
31. No check valve(s) down-stream of pump.		64. Children Should Not Use Pool w/o Adult Supervision -2" letters.	
32. Equalizer outlet(s) with approved cover or sealed.		65. IN CASE OF EMERGENCY– DIAL 911 - 1" letters.	
33. Suction outlet VGBA / ASME/ANSI compliant.		66. Phone location sign visible in pool / spa yard.	
<i>34. Dual main drains.</i>		Specific Safety Features – Safety Equipment	
Mechanical		67. Min 12' non-conductive pole within 20' of pool.	
35. Pump functioning.		68. USCG ring buoy w/ throw rope within 20' of pool.	
		69. Emergency phone location sign on pool / spa gate (if required).	

70. Emergency phone w/in 200' & not answered by onsite office.	84. Lifeguard chair(s) at least 4 feet above deck to view diving area.
71. Emergency phone functioning.	85. Boards / platforms 1/2 - 1 M with single guard & handrails.
Class A & B Pools / Spas	86. Boards / platforms over 1 M with 2 / dual guard & handrails.
72. Operator license(s) current and available.	87. Diving board(s) properly labeled.
73. Water tested every 2 hours pool / spa is in use (see log).	Bathroom & Sanitary Facilities
74. Rope and float line at shallow to deep transition.	88. Facilities clean and sanitary.
75. Dressing / sanitary facilities provided.	89. Mirror shatter resistant & soap dispenser metal or plastic.
Lifeguard / Second Responder	90. Toilet paper & holder provided.
76. Lifeguard(s) provided as required (Class A & B/slide/diving board).	91. Single use towels or hand dryer provided.
77. Current certification(s) available.	92. Covered waste receptacles.
78. Second responder on duty.	93. Floor slip resistant & sloped to floor drains.
79. Sufficient number of rescue tubes provided.	94. Private gender specific facilities.
80. Backboard with 3 tie-down straps & head immobilizer.	Glass Containers and Food
81. First aid kit with anti-disease transmission capabilities.	95. Glass containers in pool / spa yard.
82. Sufficient in-service training provided (60 minutes / week).	96. Trash containers provided.
Diving Facilities	Gas Chlorination
83. Distance between multiple boards minimum 10 feet.	97. Meets minimum standards.

**Pool enclosures not subject to HSC 757 include: hotels, youth camps, RV parks, Class B, child care, schools, etc.
Pool enclosures subject to HSC 757 are at multi-unit dwelling facilities: apartments, HOA's, condominiums, townhomes, etc.**

Class C, Class D, and Day Camp Pools & Spas Not Subject to HSC 757	ALL POOLS AND SPAS SUBJECT TO HSC 757
98. Minimum 48-inch height.	112. Minimum 48-inch height.
99. Gate(s) / door(s) self-closing and self-latching.	113. Gate(s) / door(s) self-closing and self-latching.
100. Gate(s) / door(s) not propped open.	114. Gate(s) / door(s) not propped open.
101. Openings in or under fence do not allow passage of 4" sphere.	115. Openings in chain link fabric less than 2-1/4".
102. No structures within 36" allowing fence to be scaled.	116. Latch must either be outside & minimum 60" above the ground; or
103. Opening hardware min. 42" above ground.	117. Latch must be inside only & 3" below top of gate / door; and
104. Post 10/01/99 no chain link fence after 9/1/2004.	118. No openings exceeding 1/2" w/in 18" of latch.
105. Post-10/01/99 gate(s) / door(s) open outward.	119. Latch min. 42" above ground & opens w/ key, card, or comb.
106. Post-10/01/99 No building door opening directly into pool yard or spa yard that opens outside enclosure.	120. Horizontals at least 36" apart w/gaps less than 4".
CLASS A & B AND ALL RESIDENTIAL YOUTH CAMPS	121. After 1/01/1994 horizontals less than 45" apart and no gaps greater than 1-3/4"; or
107. Minimum fence height 6 feet.	122. After 01/01/1994 horizontals min. 45" apart/gaps less than 4".
108. Fence designed to be difficult to climb.	123. No chain link after 01/01/94.
109. Openings in or under fence do not allow passage of 4" sphere.	124. Windows in wall(s) permanently closed after 01/01/1994.
110. Building door does not open outside pool/spa enclosure.	125. After 1/01/1994 gate(s) / door(s) open outward.
111. Gate(s) / Door(s) continuously & directly supervised or locked.	126. No fence cutouts w/gaps greater than 1-3/4" after 01/01/94.

Comments: _____

Inspected by (signature):	Representative (signature):
Printed Name:	Printed Name:
Date:	Date:

Onsite Time: _____ Travel Time: _____

1. 25 TAC §265.204(a)-Minimum free chlorine residual for a pool 1.0 ppm; minimum bromine level for a pool 2.5 ppm.
2. 25 TAC §265.204(a)-pH in a pool shall be maintained between 7.0 and 7.8 at all times the pool is open for use.
3. 25 TAC §265.204(a)-Cyanuric acid shall not exceed 100 ppm in an outdoor pool or spa. Cyanuric acid not allowed in an indoor pool or spa.
4. 25 TAC §265.199(c)(1)(B) & (d)(1)(B)-Depth marker numbers shall be min. 4" in height and have permanent colors for the numbers and background of the markers.
5. 25 TAC §265.199(d)(1)(E & F)-Depth markers shall be at max. & min. points of depth, at breakpoint & at 2' increments of depth change on deck and sidewalls (whenever possible) of pre-10/01/99 pools.
6. 25 TAC §265.186(c) & (d)(2)-All pools shall have a minimum of 2 entry/exits.
7. 25 TAC §265.199(c)(1)(F)-Depth markers in post-10/01/99 pools shall be no further than 25-foot intervals apart on the deck and sidewalls.
8. 25 TAC §265.199(c)(1)(I)-Depth markers for post-10/01/99 pools shall spell out "feet" or "inches" or abbreviate as "FT", "IN" and shall be 4" tall.
9. 25 TAC §265.204(a)-Minimum free chlorine residual for a pool 1.0 ppm; Minimum bromine level 2.5 ppm at all times the pool is open for use.
10. 25 TAC §265.204(a)-pH in a pool shall be between 7.0 and 7.8 at all times the pool is open for use.
11. 25 TAC §265.204(a)-Cyanuric acid shall not exceed 100 ppm in an outdoor pool or spa. Cyanuric acid not allowed in an indoor pool or spa.
12. 25 TAC §265.199(c)(1)(B) & (d)(1)(B)-Depth marker numbers shall be a minimum of 4" in height & have permanent colors for the numbers and background of the markers.
13. 25 TAC §265.199(c)(1)(F)-Depth markers shall be spaced at distances not greater than 25-foot intervals on the deck and sidewalls.
14. 25 TAC §265.199(c)(1)(I)-Depth markers for post-10/01/99 pools shall spell out in "feet" or "inches" or abbreviate as "FT", "IN" and shall be 4" tall.
15. 25 TAC §265.184(w)(1 & 2)-Post-10/01/99 wade pools shall be separate and physically set apart by min. 15' of shallow water and 35' of any deep water area; or
16. 25 TAC §265.184(w)(1 & 2)-Post-10/01/99 wade pools w/in 15' of shallow or beginner areas or w/in 35' of deep water areas shall have an enclosure.
17. 25 TAC §265.187(b)(1)(D)-The turnover rate for a post-10/01/99 wade pool shall be once per hour.
18. 25 TAC §265.204(a)-Minimum spa free chlorine residual shall be 2.0 ppm; Minimum bromine level 4.5 ppm at all times the spa is open for use.
19. 25 TAC §265.204(a)-pH in a spa shall be maintained between 7.0 and 7.8 at all times the spa is open for use.
20. 25 TAC §265.204(a)-Cyanuric acid shall not exceed 100 ppm in an outdoor pool or spa. Cyanuric acid not allowed in an indoor pool or spa.
21. 25 TAC §265.205(f)(5)-Spa the maximum water temperature shall not exceed 104 degrees Fahrenheit. A spa thermometer spa shall be available.
22. 25 TAC §265.192(m)-Spa pump shutoff switch for spa users is required no closer than 5' from the spa unless it is an air switch; shall be labeled as "Emergency Spa Shutoff" in min. 1" letters visible from spa, or location of switch on a sign visible from spa, in letters at least 1" tall.
23. 25 TAC §265.205(f)(7)(E)-All spas shall have a maximum user load sign visible to the spa user from inside the spa enclosure.
24. 25 TAC §265.205(f)(7)(B)-Post sign with message "Do Not Use Spa if the Water Temp. is Above 104 Degrees Fahrenheit" in letters min. 1" in height and clearly visible to the spa user from inside the spa enclosure.
25. 25 TAC §265.205(f)(7)(D)-Post "Children Should Not Use Spa Without Adult Supervision" sign with letters at least 2" tall and visible to spa user.
26. 25 TAC §265.205(f)(4)(A & B)-Spas shall have a min. of 2-4" in height, permanent deck depth markers.
27. 25 TAC §265.205(e)(24)(H)-A manually operated timer switch that requires exiting of the spa to operate shall be provided if there is an air blower; it shall operate the air blower and any pump connected to the air blower & shall shut off the pump and blower in 15 min. or when switched to "off."
28. 25 TAC §265.199(c)(1)(I)-Post-10/01/99 spa depth markers shall have units of measurement spelled out in feet or inches or as FT, IN and in 4" letters.
29. 25 TAC §265.190(b)-If the cover or grate of a suction outlet is missing, broken or loose, the pool or spa must be closed and the pumps shut off.
30. 25 TAC §265.190(e)(1)(B)-Only pre-10/01/99 pools and spas may have a single suction outlet and must have either an AVS or SVRD.
31. 25 TAC §265.190(j)-Check valves shall not be on the suction side of the pump, on any system that has a single source suction (excluding skimmers), or where the manufacturer of an SVRS that is used on the system does not allow check valves.
32. 25 TAC §265.190(h)-Skimmer equalizer lines must have an ASME/ANSI approved skimmer equalizer cover or be permanently sealed.
33. 25 TAC §265.190(c)-An approved suction outlet cover or grate must be ASME/ANSI approved and VGBA compliant.
34. 25 TAC §265.190(a)-Post-10/01/99 pools and spas must have 2 hydraulically-balanced suction outlets with approved covers for each suction line.
35. 25 TAC §265.189(d)-A pump and motor shall be provided for circulation of water in post-10/01/99 and pre-10/01/99 pools and spas.
36. 25 TAC §265.187(c)-Pools and spas shall have a circulation system to provide complete and uniform circulation of water to maintain water quality.
37. 25 TAC §265.187(b)(9) & (c)(7)-Pools and spas shall have a pump suction gauge, an inlet pressure gauge, an outlet gauge, and flowmeter.
38. 25 TAC §265.193(a)-If required by TDLR, pool and spa heaters and boilers shall have a current certificate of operations from TDLR.
39. 25 TAC §265.187(d)-Exposed piping pools and spas shall be labeled to identify the piping function and direction of flow.
40. 25 TAC §265.187(b)-Pools and spas shall have a circulation system to provide complete and uniform circulation of water to maintain water quality.
41. 25 TAC §265.189(e)-Post-10/01/99 pools and spas, except those with a vacuum filter, shall have a cleanable strainer or screen upstream of the pumps.
42. 25 TAC §265.204(b)(1)-Free available chlorine residual shall be determined by the use of the DPD method or its equivalent.
43. 25 TAC §265.197(a)(3) Disinfection equipment shall provide continuous and effective disinfection can be achieved under all conditions.
44. 25 TAC §265.197(a)(3)-In pools and spas the chlorine or bromine residual or other approved method of disinfection shall be maintained as required.
45. 25 TAC §265.203(b)-A pool or spa shall be opened for use only if the pool or spa bottom and/or main drains are clearly visible.
46. 25 TAC §265.197(a)(14)- Post-10/01/99 and pre-10/01/99 pool and spa skimmer baskets shall not be used as chemical feeders.
47. 25 TAC §265.194(c)-Equipment, such as skimmers, shall meet ANSI/NSFI Standard 50-1996 as applicable.
48. 25 TAC §265.184(f) & 185(c)-Colors, patterns or finishes shall not obscure objects or surfaces must be light such that an 8" disk at deepest point visible.
49. 25 TAC §265.184(u)(3) & (v)(3)-Underwater seat benches & lounges in post-10/01/99 pools and spas shall be have solid or broken stripe min. 1" wide on top leading edge of the bench or on the top leading edge of all horizontal surfaces of edges not adjoining the wall of a water lounge.
50. 25 TAC §265.186(c)(7)(C) & (10)(c)-Underwater steps shall have solid or broken stripe min. 1" wide on the top leading edge visible & contrasting color.
51. 25 TAC §265.192(e)-Each electrical line to an underwater light shall be protected with a GFCI.
52. 25 TAC §265.192(e)-Each electrical outlet in the pool yard or spa yard and in a dressing or sanitary facility shall be protected with a GFCI.
53. 25 TAC §265.192(h)-Pumps in post-10/01/99 and pre-10/01/99 pools and spas shall be both internally and externally grounded.
54. 25 TAC §265.192(k)-Electrical disconnect for pool \ spa equipment for service personnel, in sight from equipment & min. 5' from inside walls of the pool / spa.
55. 25 TAC §265.202(c)-The water supply used to fill a post-10/01/99 or pre-10/01/99 pool or spa shall be from a potable water supply system.
56. 25 TAC §265.195(b)-No direct mechanical connection between the potable water supply and a pool or spa unless protected against cross-connection.
57. 25 TAC §265.194(d) & (e)-At post-10/01/99 and pre-10/01/99 pools and spas an over-the-rim fill spout shall have a secure soft pliable end.
58. 25 TAC §265.195(c)-Drinking water (fountain) shall be provided and available to users at post-10/01/99 and pre-10/01/99 pools and spas.
59. 25 TAC §265.199(e)(1)-"NO DIVING" & the international no diving deck markers, 4 in. letters, where water 6 ft. deep feet or less; min. 2; max. 25 ft. apart.
60. 25 TAC §265.199(b)(2)-Class C pools 5 feet deep shall have a row of 4in. wide tile, a painted line, or similar means using a color contrasting with the bottom at transition from shallow to deep.
61. 25 TAC §265.199(f)(1)(A)-Signs shall be securely mounted as applicable and readily visible to the user from inside the pool / spa enclosure.
62. 25 TAC §265.199(f)(1)(B)-At Class C pools where no lifeguard is provided, a sign shall state No Diving with the international symbol min. 4in. high.
63. 25 TAC §265.199(f)(1)(C)-For pools where no lifeguard service is required, a Warning-No Lifeguard On Duty sign in 4" letters shall be posted.

64. 25 TAC §265.199(f)(1)(C)-For pools where no lifeguard is required, a children should not use pool without adult supervision sign letters min. 2" tall.
65. 25 TAC §265.199(j)(5)-A sign must be installed inside the pool yard or spa yard and state in letters at least 1" tall In Case of Emergency Dial 911.
66. 25 TAC §265.199(j)(5)-If telephone not readily visible a sign in the pool/spa shall include a description of the location of the (emergency) telephone.
67. 25 TAC §265.199(i)(1)(A)-Pools shall have at least 1 non-conductive, non-telescopic reaching pole that is at least 12 feet long and shall have a body hook or shepherd's crook with blunted ends attached to it.
68. 25 TAC §265.199(i)(1)(B)- Pools shall be equipped with an USGS approved ring buoy with an outside diameter of 15" to 24" with attached throwing rope 1/4" to 3/8" in diameter, with a length at least 2/3 the maximum width of the pool.
69. 25 TAC §265.199(j)(4)-A sign on the exterior of gate or door, or on the fence or wall next to gate or door is required if the phone is outside pool yard.
70. 25 TAC §265.199(j)-An emergency telephone that is answered by an on-site office does not meet the requirements.
71. 25 TAC §265.199(j)-A telephone capable of immediately summoning emergency service within 200' of the pool or spa water is required.
72. 25 TAC §265.203(a)-Class A & B pools, or Class D pools at Class A or B facility, shall be under the supervision and direction of a certified operator.
73. 25 TAC §265.204(c)-When a Class A or B facility is open, a test for disinfectant level and pH shall be conducted & logged at least every 2 hours.
74. 25 TAC §265.199(b)(1)(B)-In Class A and B pools over 5' deep a rope and float line is required above the 5-foot depth.
75. 25 TAC §265.201(e)-Adequate dressing and sanitary facilities shall be provided at all Class A and Class B facilities.
76. 25 TAC §265.199(g)(9)-Lifeguards & 2nd responders are required at Class A pools during competitive events; Class B pools when open & at Class C pools with a diving board or slide that is not locked or chained to prevent use.
77. 25 TAC §265.199(g)(7)-At any pool with lifeguards, each staff person's current certification including expiration dates at each facility.
78. 25 TAC §265.199(g)(4)(B)-When a lifeguard is provided an additional lifeguard, or second responder is also required.
79. 25 TAC §199(h)(2)-Lifeguard(s) shall have a sufficient standard rescue tube(s) or buoy(s) with attached rope/strap and other necessary equipment.
80. 25 TAC §265.199(i)(2)-Pools that have lifeguard(s) shall have min. one backboard with a min. 3 tie down straps and head immobilizer.
81. 25 TAC §265.199(i)(3)-Pools with lifeguards shall be equipped with a 24-unit OSHA approved first aid kit with disease cleansing kits.
82. 25 TAC §265.199(g)(6)-Lifeguards & 2nd responders shall have min. 60 min. in-service training per week.
83. 25 TAC §265.186(e)(6)-The min. distance between multiple diving boards on shall be 10' as measured from center to center.
84. 25 TAC §265.199(h)(1)-A pool with diving board(s) shall have at least 1 lifeguard chair elevated at least 4 feet above the pool deck.
85. 25 TAC §265.186(e)(11)-Post-10/01/99 pools all platforms or diving equipment 1/2-1 M in height shall have guardrails 30" above the diving board.
86. 25 TAC §265.186(e)(11)-Post-10/01/99 pools, all platforms or diving equipment 1 meter or more tall shall have dual guardrails that are approximately 18" and 36" above the diving board.
87. 25 TAC §265.186(e)(9)-Diving boards on post-10/01/99 pools a label with manufacturer's name and address, board length, identity as to diving or jump board, fixed fulcrum setting, reference to applicable articles in ANSI/NSPI 1-1991, weight limitations and date of installation is required.
88. 25 TAC §265.201(c)-Dressing and sanitary facilities shall be cleaned as necessary to maintain sanitary conditions at all times.
- 89-92. 25 TAC §265.201(h)(1-5)-Sanitary facilities shall have metal or plastic soap dispensers, shatter resistant mirrors, toilet paper and holders, covered waste receptacles, and single use hand drying towels or hand drying devices.
93. 25 TAC §265.201(e)(4)-Post-10/01/99 Class A or B facilities shall have slip-resistant floors and sloped floor drains to ensure positive drainage.
94. 25 TAC §265.201(e)(1)- Post-10/01/99 Class A or B facilities shall have separate dressing and sanitary facilities for each gender.
95. 25 TAC §265.202(b)-Glass containers shall not be allowed on a deck, in a pool or spa, or elsewhere in a pool yard or spa yard.
96. 25 TAC §265.202(c)-Trash containers shall be provided where food and/or beverages are allowed.
97. 25 TAC §265.198-Regulations governing gas chlorination systems can be found at: <http://www.dshs.state.tx.us/poolspa/docs/poolrules.doc>.
98. 25 TAC §265.200(c)(1)(A)-Pool yard or spa yard enclosure must measure a minimum height of 48" measured from the ground outside of the fence.
99. 25 TAC §265.200(c)(2)(A)- All gates and doors must self-close & self-latch released from its fully open position to 6" from the fully closed position.
100. 25 TAC §265.200(d)-The enclosure gate or door may not be propped open or to remain propped open unless agent, employee, or contractor is present and doing construction, maintenance, or repair work in the pool yard or spa yard that reasonably requires the gate to be propped open.
101. 25 TAC §265.200(c)(1)(B)- Pool or spa enclosure shall have no openings in or under the enclosure that will allow the passage of a 4-inch sphere.
102. 25 TAC §265.200(c)(1)(C)-Pool or spa fence shall have other structures within 36 inches, measured horizontally, from outside of enclosure.
103. 25 TAC §265.200(c)(2)(C)-Pool or spa fence shall have hand-activated latching hardware at least 42" above the deck or walkway.
104. 25 TAC §265.200(c)(1)(D)-An enclosure fence constructed after September 1, 2004 may not use chain link.
105. 25 TAC §265.200(c)(2)(B)-Gates on enclosures constructed after 10/01/99 must open outwards.
106. 25 TAC §265.200(c)(1)(E)-Doors or gates of a building that have means of egress outside the pool yard are not allowed at a post-10/01/99 pool or spa.
107. 25 TAC §265.200(a)(3)(A)-The enclosure at a Class A, Class B & residential youth camp shall be a min. 6' in height measured outside the fence.
108. 25 TAC §265.200(a)(3)(C)-Class A, Class B and residential youth camp enclosure shall be designed and constructed so that it cannot be readily climbed.
109. 25 TAC §265.200(a)(3)(B)-Class A, Class B and residential youth camp enclosure shall have no openings through which a 4-inch diameter sphere can pass.
110. 25 TAC §265.200(a)(2)-A building at a Class A, Class B or residential youth camp that is part of a pool or spa enclosure shall not have any door or gate opening to the outside of the pool yard enclosure and shall not contain any gas chlorine containers.
111. 25 TAC §265.200(a)(3)(D)-Enclosure gates and doors at Class A, Class B and residential youth camp pools and spas shall be directly and continuously supervised by staff, or locked to prevent unauthorized entry.
112. HSC 757.003(b)-Enclosure shall be a minimum height of 48 inches from the ground on the side away from the pool or spa.
113. HSC 757.004(a)-All gates of a pool or spa enclosure at pools and spas must have a self-closing and self-latching device.
114. See #100
115. HSC 757.005(a)(1)-Chain link fencing may not allow passage of 2-1/4" sphere through fabric.
116. HSC 757.004(b)-Latch must be at least 60" above the ground; or
117. HSC 757.004(b)(1)-Latch may be installed lower if latch is on the pool side & is min. 3" below the top of gate; and
118. HSC 757.004(b)(2)-has no opening greater than 1/2 inch in any direction within 18 inches from the latch.
119. HSC 757.004(c)- Latch may be located 42" or higher if the gate cannot be opened except by key, card, or combination on both sides of the gate.
120. HSC 757.005(a)(2)-Distance between the tops of the horizontal members is at least 36" openings may not allow passage of 4" diameter sphere.
121. HSC 757.003(e)-Distance between the tops of the horizontal members < 45" no gaps allow passage of 1-3/4" sphere.
121. HSC 757.003(e)-Distance between the tops of the horizontal members min. 45 inches, no openings allow passage of 4" sphere.
122. HSC 757.003(d)-Enclosure distance between the tops of the horizontal members is ≥45 inches, the openings may not allow passage of 4" sphere.
123. HSC 757.003(f)-Enclosure shall not be constructed of chain link fencing materials.
124. HSC 757.007-A wall of a building may not be used as part of an enclosure unless all ground floor windows in the wall is permanently closed/unable to open.
125. HSC 757.004(a)-Gates of pool or spa enclosure and must have a self-closing and self-latching device and open outward away from the pool or spa.
126. HSC 757.003(g)-There can be no decorative cutouts with openings greater than 1-3/4 inches in any direction in the enclosure.