



HEALTH AND FOOD SAFETY DIVISION

550 Landa Street
 New Braunfels, TX 78130
 Office: 830-221-4041
 Email: health@newbraunfels.gov
www.newbraunfels.gov

**Public
 Swimming Pools and
 Spas**

Facility Name:		Date:	
County: COMAL / GUADALUPE		Phone:	
Facility Address:		City: NEW BRAUNFELS	
Mailing Address:		State/Zip:	
Permit Number:	<input type="checkbox"/> Indoor <input type="checkbox"/> Outdoor	<input type="checkbox"/> Class A <input type="checkbox"/> Spa	<input type="checkbox"/> Class B <input type="checkbox"/> Wade
<input type="checkbox"/> Class C <input type="checkbox"/> w/PIWF			
Inspection Type: <input type="checkbox"/> Routine <input type="checkbox"/> Complaint <input type="checkbox"/> Re-Inspection <input type="checkbox"/> Pre-Licensing <input type="checkbox"/> Other (specify):			

“X” indicates an alleged deficiency

“COS” indicates corrected on-site

SWIMMING POOL OR WADE POOL

1. Chlorine 1.0 to 8.0 ppm	
2. Bromine 3.0 to 10.0 ppm	
3. pH 7.0 to 7.8	
4. Cyanuric Acid: Max 100ppm	
5. Water clarity sufficient / no algae present	
6. DPD test kit in use is reliable and properly stored	
7. Deck & sidewall depth markers permanent with 4” numbers	
8. Markers at max. & min. depth, breakpoint & 2” depth intervals	
9. Minimum 2 entry / exits	
10. Depth markers no more than 25 feet	
11. Depth markers – feet and / or inches in 4” letters	
12. Wade pool 15ft from shallow /35ft from deepwater areas	
13. Wade pool fenced separately from pool / spa	
14. Wade pool with independent circulatory / sanitization system	

SPA

15. Chlorine 1.0 to 8.0 ppm	
16. Bromine 4.0 to 10.0 ppm	
17. pH 7.0 to 7.8	
18. Cyanuric acid outdoor spa (100 ppm or less)	
19. Water clarity sufficient / no algae	
20. Water temp 104F or less / spa thermometer available	
21. Emergency shutoff switch not <5’ & not >10’ from spa	
22. Manually operated 15min timer switch available to users	
23. Depth markers ft and / or inches in 4” letters	

ELECTRICAL

24. Pump(s) grounded and bonded	
25. Service electrical disconnect with in sight of pool / spa equipment	
26. ORP meter in use / mV reading 600 -900 mV	

SUCTION OUTLETS IN POOLS & SPAS

27. Suction outlet cover(s)/grate(s) intact and in place	
28. Dual Suction outlets or single suction outlet with SVRS	

CIRCULATION EQUIPMENT & MECHANICAL

29. Pump and filter functioning	
30. Circulation equipment has pump vacuum or vacuum pressure gauge	
31. Filter inlet and outlet gauge, and flowmeter in place	
32. Exposed piping labeled with function & directions of flow	
33. Written operation & maintenance instructions provided	
34. Pool/spa heater has TDLR operation certificate	
35. No user access to heater controls	
36. Skimmer basket not used to dispense chemicals	
37. Skimmer covers in place	

FILL WATER / DRINKING WATER / OPERATION

38. 1x1 stripe on leading edge of benches & water lounges	
39. 1x1 strip on leading edge of underwater / swimout steps	
40. Fill water public water supply	
41. Water distribution system protected against backflow	

BATH HOUSE & SANITARY FACILITIES

42. Facilities clean and sanitary	
43. Mirror shatter resistant & soap dispenser metal or plastic	
44. Toilet paper and holder provided	
45. Single use towels or hand dryer provided	
46. Covered waste receptacles	
47. Floor slip resistant & sloped to floor drains	
48. Private gender specific facilities	

GLASS CONTAINERS & FOOD

49. Glass containers not in pool / spa yard	
50. Trash containers provided	

AQUATIC PLAY FEATURES

51. Wave pool has rope and float line restricting access to caisson wall	
52. Wave and Surf pools have 2 emergency shut off switches	

NO DIVING MARKERS & TRANSITION LINE

53. Min. 2 - 4” “NO DIVING” letters & symbol no more than 25’ apart	
54. 4”x 4” line on bottom at transition from shallow to deep	

SIGNS

55. Sign(s) visible to pool/spa user in all areas of pool/spa yard	
56. No Diving in 4" letters & symbol where applicable	
57. Warning – No Lifeguard on Duty as applicable - 4" letters	
58. In Case of Emergency Dial 911 – 4" letters	
59. Emergency "Phone" location sign visible in pool/spa yard	
60. Pool / spa maximum user load – 2" letters	
61. Emergency spa shut off – 2" letters	
62. Location of emergency phone or device when applicable – 2" letters	
63. Pets in pool / spa prohibited – 2" letters	
64. Persons less than 14yrs not in pool without adult supervision – 2" letters	
65. Extended breath holding activities prohibited – 2" letters	
66. Glass items not allowed – 2" letters	
67. Changing diapers within 6' of pool prohibited – 2" letters	
68. Do not swim if ill with diarrhea in past 2 weeks – 2" letters	
69. Do not use spa if water temp. is over 104°F – 1" letters	

SPECIFIC SAFETY FEATURES

70. Emergency phone within 200' and not answered by onsite office	
71. Emergency phone operable / charged	
72. Min. 12' non-conductive reaching pole within 20' of pool	
73. USCG ring buoy with throw rope within 20' of pool	
74. Lifeguards provided at pools as required	

CLASS A & B AND ALL RESIDENTIAL YOUTH CAMPS

75. Minimum fence height 6 feet	
76. Fence designed to be difficult to climb	
77. Opening in or under fence do not allow passage of 4" sphere	
78. Gate(s) / door(s) continuously & directly supervised or locked	
79. Service gate not in use, closed and locked	

**CLASS C, D & DAY CAMPS POOLS / SPAS
NOT SUBJECT TO HSC757**

80. Minimum fence height 48" (4 feet)	
81. Gate(s)/door(s) self-closing and self-latching	
82. Openings do not allow passage 4" sphere	
83. Hardware on gates and doors at least 3-1/2ft above ground	
84. Gate not propped open	
85. Gate or door open outward away from pool / spa	
86. Service gate not in use closed and locked	
87. No building in pool/spa yard with exits out of pools/spa yard	

ALL POOLS & SPAS SUBJECT TO HSC757

88. Minimum height 48"	
89. Gate(s)/door(s) not propped open	
90. Service gate not in use, closed and locked	
91. Latch either on outside of gate & min 60" above the ground	
92. Latch inside gate 3" below the top of gate or door; and	
93. No openings exceeding 1/2 "within 18" of the latch	
94. Latch min 42" above ground & opens with key, card or comb	
95. Horizontals at least 36" apart with gaps less than 4"	
96. After 1/1/94 horizontals ≥ 45" apart/gaps ≤ 4", or	
97. After 1/1/94 horizontals < 45" gaps no greater than 1-3/4"	
98. After 1/1/94, No chain link fencing	
99. After 1/1/94, gate(s) / door(s) open outward	
100. After 1/1/94 No fence cutouts w/ gaps greater than 1-3/4"	

Signs that are in bold letters are not required unless signs are replaced after 01/01/2021 or the facility constructed on or after 01/01/2021. A complete list of all new sign requirements can be found at: <https://dshs.texas.gov/poolspa/guidance.aspx>.

Comments: _____

Inspected by(signature):	Owner/Operator(signature):
Printed Name:	Printed Name: